MIMETA ENT REV. E B/L 8/30 MPS LH2, LOA SYSTEM

Critical Item: Relief Valve

Find Number: A105956

Criticality Category:

SAA No: 09PP03-001 System/Area: LH2 MPS/LOA

NASA

PMN/ \$72-0685-5 Orbiter Helium Part No: 79K80162-7

Name: Anti-Ice Panel

Mfq/ Anderson-Greenwood 79K06063/79K40023 Drawing/

Part No: 81JS68-8 Sheet No:

Function: Provides overpressure protection for the GHe system downstream of regulator A105951.

Critical Failure Mode: Fail open (continuous vent). FM. No. 09PP03+001.018

Failure Effect: Loss of heated GHe to the LH2 and LOX prepress lines for anti-ice purposes. Possible damage to the Orbiter TPS from falling ice. Failure is detectable by pressure transducer A105955.

## Acceptance Rationale

## Design:

- o This relief valve is operated within all design specifications.
- o This component is only Criticality Category 2 when the ambient temperature is 36°F or below because the unheated backup helium supply is not effective at these temperatures.
- o Component Specifications:

	Rated	<u>Actual</u>
SET Pressure (psig)	178-264	237
Flow (scfm)	2078	695 (nominal)
Temperature (°F)	-20 to +550	Ambient on the MLP

- o The burst pressure is 4 times rated pressure (1056 psig).
- o The relief valve body and spring are constructed of 316 SST, internal metal parts are made of 300 series SST, the seat and seals are Teflon.

SAA09PP03-001
REV. E
B/L 8/30
MPS LHZ, LOA SYSTEM

Relief Valve, A105956 (Continued)

## Test/Inspection:

- o File VI verifies the following:
  - Functional operation of the primary purge prior to each launch and at component replacement. The purge is verified via pressure switch indication and must satisfy a temperature specification after heater activation.
  - Functional operation of the redundant purge prior to each launch and at component replacement. The purge must satisfy a purge pressure specification.
- O The manufacturer's certification test requirements included the following tests:
  - Proof
  - Leak
  - Functional
- O Drawing 79K12402 requires that the component be tested annually and at component replacement. Tests to consist of internal leak test plus crack and reseat pressure tests.

## Failure History:

o PRACA - There were 2 Problem Reports for this type component found in the PRACA Data Base.

No failures found in the critical failure mode.

o GIDEP - The GIDEP Failure Data Interchange System has been researched, and no data on this component was found.